



1. COMPACTED COPPER CONDUCTOR
2. CONDUCTOR SEMI-CON
3. XLPE INSULATION
4. INSULATION SEMI-CON
5. COPPER TAPE SCREEN
6. NHLSFR BEDDING
7. NHLSFR OUTER SHEATH

## NEELKANTH CABLES LIMITED

### DATA SHEET

#### THREE CORE XLPE UNARMOURED, ZERO HALOGEN EMISSION, REDUCED SMOKE EMISSION, REDUCED FLAME PROPAGATION (NHLSFR) MEDIUM VOLTAGE CABLE

Three Core Cable Description : Copper Conductor, Semi-conducting conductor Screen, XLPE Insulated, Semi-conducting Insulation screen, Metallic screen over Individual Core, NHLSFR Inner Sheath, Overall NHLSFR (Polyolefin) Outer Sheathed, Medium Voltage Unarmoured Cable.

Make	NEELKANTH CABLES LIMITED
Reference Standard	As per IEC 60502-2
Voltage Rating ( U <sub>o</sub> / U)	3.6/6 kV
Maximum Operating Voltage ( U <sub>m</sub> )	7.2 kV
Operating Temperature	90°C
Max. Temp. During Short Circuit	250°C

**Range of Product** Three Core 10 Sq.mm up to 300 Sq.mm

#### Application

These Medium Voltage Three Core Cables are Designed for Electricity Power Distribution, Suitable for Installation in Power Supply Stations, Commercial, Industrial and Urban Residential Networks, Indoors and in Cable Ducts, Outdoors, Undergrounds and as well as for Installation on Cable Trays for industries, Switchboards and the power Stations.

#### Construction

<b>Conductor</b>	Annealed Plain Copper Compacted Round Stranded Conductors to carry Current and withstand Pulling Stresses During Cable Laying. Conductors Complying with IEC 60228 Class-2
<b>Inner Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over Conductor to Smooth the Electric Field at the Conductor and Firmly Bonded to the Insulation to exclude all air voids, and Prevent Concentration of electric field of the interface between the Insulation and the Inner Semi-Conductor. Semi-Conducting Compound Complying with IEC 60502-2
<b>Insulation</b>	The Insulation of XLPE ( Cross-Linked Polyethylene ) Rated Voltage, Lightning Overvoltage, Switching Overvoltage, and Withstand the Various Voltage Field Stress During the Cable Service Life. as per SANS IEC 60502-2
<b>Core Semi-Conducting Screen</b>	Extruded Layer of Semi-Conducting Screen over the Insulation. The Screen is Tightly Fitted to the Insulation to Exclude all air Voids, Prevent Concentration of electric field of the interface between the Insulation and the Semi-Conductor. Semi-Conducting Compound Complying with IEC 60502-2
<b>Metallic Screen</b>	The Metallic Screen Shall Consist of either Copper Tapes or a Concentric layer of Copper Wires. The Metallic Layer may be applied over the Individual Cores. Metallic Screen Provide no Electric Field outer side the Cable, An Active Conductor for the Capacitive and Zero-Sequence short-circuit current, and Contribution to Mechanical Protection. as per IEC 60502-2
<b>Filler (Optional)</b>	PVC or Polypropylene yarn
<b>Inner Sheath/Bedding</b>	The Inner-sheath Comprises a layer of Extruded as per Requirement NHLSFR (Polyolefin) Applied Under the Armour, Inner-sheath Compound Complying with SANS 1411-5
<b>Outer Sheath</b>	The Over all Outer-sheath Comprises a layer of Extruded as per Requirement NHLSFR (Polyolefin) and Applied Over the Armour to Insulate the Metallic Screen From the Surrounding Medium, to Protect the Metallic Screen From Corrosion, to Reduce the contribution of cables to Fire Propagation, and Contribute to Mechanical Protection. Outer sheath Compound Complying with SANS 1411-5. Colour: Black with White Stripe or as per Requirement

#### Technical Characteristic

Voltage Grade	3.6/6 kV
Test Voltage	12.5 kV for 5 Minute ( 3.5 U <sub>o</sub> r.m.s)
Temperature Rating	-15°C to +90°C
Partial Discharge	IEC 60885-3
Resistivity of Semi-conducting Screen	IEC 60502-2
Reduced Flame Retardent	IEC 60332 Part-3-24
Zero Halogen Emission	SANS 60754-2
Minimum Installation Bending Radius	15(D+d) D= Nominal Diameter of the Cable, d=Nominal Diameter of the Conductor

#### Marking & Packing

Marking over the sheath	NEELKANTH CABLES, CABLE SIZE, 3.6/6 kV CU/XLPE/CTS/NHLSFR/NHLSFR ELECTRIC CABLE, YEAR OF MANUFACTURING
Sequentail Length Marking	Shall be provided on outer sheath at every one Meter
Cable Length	Multiple of 250/500 or as per Requirement
Type of Drum	Wooden Drum Fully Packed with Lagging

Data Sheet No.	10149	Page 1 of 1
Version	01	Issue Date: 29/04/2021